

DC protection research trends opportunities and challenges

September 27, 2019

Dirk Van Hertem, KU Leuven

PROgress on Meshed HVDC Offshore Transmission Networks

Status DC grid protection

- Algorithms for detecting faults for detecting faults are available, including for backup, differential, busbar, with and without communication,...
 - Different types of algorithms can operate on the same device resulting in compound protection device
 - Different protection strategies are developed
 - DC IED have been implemented and lab tested: functionally ok
 - First systems are implemented
-
- ➔ no need for further research?




Remaining needs for algorithms

- Optimization of different algorithms still needed
 - From good enough to ensuring the combination gives "the best" outcome
- Continued focus on robustness, fault tolerance, measurement requirements, delays, filtering,...
- Most research on cable systems → OHL & mixed systems
- Flexibility to changing conditions
 - Without adaptive protection?
 - Reclosure
- Taking into account new features
 - E.g. pro-active mode
- Most research towards selective protection, but other options (e.g. using fault-blocking converters)



Remaining needs for relays/IED

- Further industrialization steps
 - Making it ready for use in the substation
- Is the IED part of the breaker, or a separate device?
- Which measurements are required?
- Making use of measurement signals from breakers and converters or do we rely on dedicated measurements?




Remaining needs wrt to communication

- Communication within the substation
- Communication with converters
 - → advanced converter behavior during faults
- Communication/interfaces with measurement equipment
- IEC 61850 (and other)
 - Currently, DC is not supported
 - How to define the protection features?
 - Interfacing with other (AC system)






Remaining needs: multi-vendor and multiple protection strategies






Remaining needs wrt standardization

- Testing and test procedures
- Protection classes
- We need to define functional requirements & interfaces
 - Which signals to send/receive
 - To converters
 - To (all types of) breakers
 - Inductor part of breaker?
 - Relay part of breaker?
- Definitions
 - What should be on the nameplate of a relay
 - What should be on the nameplate of a DCCB



Remaining needs for grid codes

- Grid side expectations on various equipment parameters
- Fault current levels
- Voltage and current requirements
- Converter behavior
- What data should be exchanged?
- Which models should be exchanged?
- HVDC Grid Fault Ride Through Scenarios:
 - Fault Ride Through Scenario 1 (DC-FRTS1)
 - All converters are prohibited from blocking.
 - Fault Ride Through Scenario 2 (DC-FRTS2)
 - Remote converters are prohibited from blocking.
 - Fault Ride Through Scenario 3 (DC-FRTS3)
 - All converters can be blocked temporarily.



Remaining needs wrt to measurement equipment

- Voltage measurements:
 - Location (relative to the busbar, inductance, poles,...)
 - Amount
 - Accuracy, bandwidth, delay
- Current measurements:
 - Location (relative to the busbar, inductance,...)
 - Amount
 - Accuracy, bandwidth, delay




Remaining needs wrt to modeling and simulations for protection studies

- DC converters are still hard to simulate
 - Level of detail shared for protection studies?
- Behavior during the fault needs to be fully understood, in terms of default behavior and the degree of freedom available
 - Did we consider actual fault waveforms
- Different converter types/implementations/topologies might have different behavior
- DC choppers and their interaction with the grid
- Interaction of protection equipment (including inductors) with the system can cause instabilities, and require the right models and simulation tools



Remaining needs wrt to topology development

- AC system developments are largely rule based
- Significant learning based on probability and impact
- Same approach to be used for DC grids
 - Busbar topologies
 - Nr of connections, redundant paths
 - ...



Conclusions

- DC grid protection has reached the stage that a solution is found
- This solution might need refinement
- Further developments are expected
- Two main lines of thought:
 - Industrialization
 - Agreements on the expected behavior will require adaptations
- End solution should be:
 - “multi-vendor”
 - Integrated in the existing substation infrastructure (including IEC 61850,...)
 - Future ready (grid extensions)

