



PROMOTiON

PROGRESS ON MESHED HVDC
OFFSHORE TRANSMISSION
NETWORKS



How to reduce the size of platforms with HVDC GIS?

2019-11-27, WindEurope Offshore 2019, Copenhagen
Michael Gatzsche (PROMOTiON WP15, ABB Power Grids)



© PROMOTiON – Progress on Meshed HVDC Offshore Transmission Networks
This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 691714.



- What is Gas-Insulated Switchgear (GIS) and its benefit for platforms?
- What is special about HVDC GIS?
- What is PROMOTioN WP15's mission on HVDC GIS?
- Conclusion & Summary



What is Gas-Insulated Switchgear (GIS) and its benefit for platforms?



© PROMOTioN – Progress on Meshed HVDC Offshore Transmission Networks
This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 691714.

What is Gas-Insulated Switchgear (GIS) and its benefit for platforms?

Basics



©ABB

- Using pressurized gas instead of ambient air for insulation (sulfur hexafluoride or eco-efficient alternatives)
- Massive space savings (up to 90 %)
- Very robust against environmental impacts
- Alternating Current (AC): GIS introduced in 1967, today: proven technology with 100 000+ GIS bays in operation



©ABB



© PROMOTiON – Progress on Meshed HVDC Offshore Transmission Networks
This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 691714.

2019-11-27

4


GIS Advantages for Platforms

HVDC GIS

A GIS installation can be built with a much **higher degree of compactness** and significantly **lower sensitivity to ambient factors** than with air-insulated switchgear (AIS).

The most obvious cost-saving potential can be found on **off-shore converter platforms** where the required air-clearance for AIS leads to much larger and heavier off-shore structures.

By applying HVDC GIS, the **volumetric space** of the switchgear installation can be **drastically reduced** e.g. by 70%- 90%, the platform size by 10 %.





What is special about HVDC GIS?




© PROMOTiON – Progress on Meshed HVDC Offshore Transmission Networks
This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 691714.

What is special about HVDC GIS?

AC ⚡ DC: Electrical Field

Electric Engineering





$$I = \frac{U}{R} + C \frac{d(U)}{dt}$$

$$\tau = RC = \frac{\epsilon_0 \epsilon_r}{\sigma}$$

$t = 0$ ("AC") $t \rightarrow \infty$ ("DC")

Implications for GIS



What is special about HVDC GIS?

20 Years HVDC GIS



**First 150 kV GIS
Gotland 2**




**First long-term test
BPA (USA)-ABB**



**First 250 (500) kV GIS
KII – link (Japan)**



**New generation
(DE)**




First research



**150 kV GIS
Gotland 3**



**First long-term test
(Japan)**



**New generation
(CH)**



**New generation
(Japan)**

1980

1983

1987

1990

1995

2000

2013

2014

2018



© PROMOTiON – Progress on Meshed HVDC Offshore Transmission Networks

This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 691714.

2019-11-27

8

What is PROMOTiON WP15's mission on HVDC GIS?



© PROMOTiON – Progress on Meshed HVDC Offshore Transmission Networks
This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 691714.

Main objectives (WP15)

Full scale technology demonstrations of HVDC gas insulated systems

- To increase the **Technology Readiness Level (TRL)** from 6 to 8 (out of 9) for HVDC GIS equipment
- To carry out **long term testing of full power HVDC GIS** according to developed test requirements/procedures and using developed monitoring and diagnostic methods
- To develop **recommendations for specifying** gas-insulated (GIS) HVDC systems
- To develop **testing requirements, procedures and methods** based on simulation analysis, real HVDC onshore and offshore experiences, and also based on CIGRE work (JWG D1/B3.57: Dielectric Testing of Gas-Insulated HVDC Systems).
- To **develop monitoring and diagnostic methods** for HVDC GIS to ensure a safe operation.
- To **evaluate performance of SF₆ alternatives**.
- Use results to improve models and develop **understanding of failure modes**.




What is PROMOTioN WP15's mission on HVDC GIS?

Prototype installation test

ABB

HIGH VOLTAGE PRODUCTS
HVDC gas-insulated switchgear



Bus-ducts and high voltage DC conductors


Disconnect, earthing and fast acting earthing switches

Bushings

Current- and voltage measurement sensors

Technical data

Nominal DC voltage	kV	320
Rated DC voltage	kV	350
Rated lightning impulse withstand voltage	kV	1050
Rated switching impulse withstand voltage	kV	950
Rated DC withstand voltage	kV	610
Rated normal current	A	4000
Rated short-time withstand current	kA	64
Rated duration of short circuit	s	1
Rated peak withstand current	kA	160
Ambient temperature range	°C	-30...+40



HV Connection
DC Bushing

Extension
option

AC Heating Current
3 conventional CTs





HVDC GIS prototype installation test procedure



Blocks:

- constantly 420 kV DC for 60 days (nominal voltage +30%, rated voltage +20%)
- Cycles with 0 A (ZL → cold) and 4000 A (HL → thermal stress)
- Superimposed Lightning Impulse and Switching Impulse at the end of each block




Monitoring
Gas density
PD: UHF/Optical/HFCT
Arc Detection
Enclosure Temperature

ZL = zero load (zero heating)
HL = high load (continuous heating)
LC = load cycle
SIM = Superimposed switching and lightning impulse voltage test
ACPD = AC partial discharge measurement at U_{ac}

What is PROMOTioN WP15's mission on HVDC GIS?

HVDC monitoring and diagnostic methods







Partial Discharge (PD)

- A localized voltage breakdown in gas
- A current pulse with a very fast rise time <1 ns

Fundamental Questions

- Type of sensors (HFCT, Antennas)?
- Correlation AC and DC?
- Number and where to install sensors?
- Which other parameters can be monitored?

Development of M&D System based on HFCT



© PROMOTioN – Progress on Mesh
This project has received funding from


the European Union's Horizon
research and innovation programme under grant agreement No 691714.




PD behavior for SF6 and alternative gases

SF6 has a very high GWP (23900), thus regulators, manufacturers and users strive to replace it with eco-efficient alternatives

PD behavior is principally comparable to SF6, but differences in polarity effect and time between pulses occur




Negative polarity



100kV

Positive polarity





Summary and Conclusions



© PROMOTiON – Progress on Meshed HVDC Offshore Transmission Networks
This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 691714.

Summary and Conclusions

- High-Voltage Gas-Insulated Switchgear is an efficient and proven technology to reduce the size of AC substations
- HVDC GIS is a new technology about to be introduced to the market
- The size and cost of platforms in meshed HVDC offshore transmission networks can be significantly reduced by utilizing HVDC GIS
- What PROMOTioN's WP15 delivers for HVDC GIS technology:
 - Increase the Technology Readiness Level (TRL) from 6 to 8 (out of 9)
 - Specify and carry out a full scale long-term test (+1 year)
 - Investigate and develop monitoring and diagnostic methods as well as eco-efficient SF6 alternatives



APPENDIX

DISCLAIMER & PARTNERS

COPYRIGHT

PROMOTioN – Progress on Meshed HVDC Offshore Transmission Networks
MAIL info@promotion-offshore.net WEB www.promotion-offshore.net

The opinions in this presentation are those of the author and do not commit in any way the European Commission

PROJECT COORDINATOR

DNV GL Netherlands B.V.
Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
Tel +31 26 3 56 9111
Web www.dnvgl.com/energy

CONTACT

Dr.-Ing. Michael Gatzsche
R&D Senior Engineer
ABB Power Grids Switzerland Ltd
Elias-Canetti-Strasse 7, 8050 Zürich, Switzerland
michael.gatzsche@ch.abb.com
+41 79 347 25 54

PARTNERS

DNV GL Netherlands B.V., ABB AB, KU Leuven, KTH Royal Institute of Technology, EirGrid plc, SuperGrid Institute, Deutsche WindGuard GmbH, Mitsubishi Electric Europe B.V., Affärsverket Svenska kraftnät, Alstom Grid UK Ltd (Trading as GE Grid Solutions), University of Aberdeen, Réseau de Transport d'Électricité, Technische Universiteit Delft, Equinor, TenneT TSO B.V., Stiftung OFFSHORE-WINDENERGIE, Siemens AG, Danmarks Tekniske Universitet, Rheinisch-Westfälische Technische Hochschule Aachen, Universitat Politècnica de València, SCiBreak AB, Forschungsgemeinschaft für Elektrische Anlagen und Stromwirtschaft e.V., Ørsted Wind Power A/S, The Carbon Trust, Tractebel Engineering S.A., European University Institute, S.A., European Association of the Electricity Transmission & Distribution Equipment and Services Industry, University of Strathclyde, S.L., Prysmian, Rijksuniversiteit Groningen, MHI Vestas Offshore Wind AS, Energinet, Scottish Hydro Electric Transmission plc, SCiBreak AB

