

WP16

How to avoid converter controller interactions

WindEurope Offshore 2019

27.11.2019 – Copenhagen

Philipp Ruffing – RWTH Aachen




UNIVERSIDAD
POLITECNICA
DE VALENCIA


Orsted



Work Packages






Work Packages



Stability in Converter-Dominated Networks


- Sustained oscillations have been observed in converter-dominated networks
 - VSC and AC grid
 - Offshore HVDC link and wind farm
 - Related to resonance interactions
 - Interactions of a VSC converters with grid resonance
 - Interactions between different VSC converters
- Often referred to as harmonic instability
- Or Converter driven stability



Source: PES General Meeting 2019, Atlanta

Methods for the Investigation of Controller Interactions


Hardware-in-the-Loop (HiL)



Operation and control coordination between HVDC networks and Offshore wind power plants

- Grid & converter configurations
- Interaction MTDC network and OWP
- MTDC and OWP fault handling
- AC grid support with meshed offshore grids

Impedance-based Stability Criterion




Assessment of the “harmonic” stability in offshore collector grids

- Development and validation of impedance models of wind turbine and HVDC converters
- Analysis of harmonic stability and potential interactions of active components and the AC grid

Impedance-based Stability Criterion

Stability analysis methods

- State-space modeling
 - Time domain
 - Frequency domain
- No consensus yet which method is applicable



Harmonic Resonance Analysis

Analytical derivation of converter impedance models

Analytical Method (Deliverable 16.5):

Impedance derived via linearized converter models
(including controls)


$$Z(s) = \frac{K_m V_{dc} [H_i(s - 2\pi f_1) - jK_d] + sL}{1 - K_m V_{dc} [(H_i(s - 2\pi f_1) - jK_d)I_1 + M_1]T_p(s - 2\pi f_1)}$$

- 👍 Insight about root causes of instabilities
- 👎 Full knowledge about converter & controllers needed

Converters under study:

- Wind Turbine Converters
- MMC-HVDC Converters
- DRU-connected Wind Turbines

<https://www.promotion-offshore.net/results/deliverables/>




Harmonic Resonance Analysis

Impedance-based Stability Criterion

- Harmonic stability is assessed in the frequency domain
- System is modelled as two subsystems having frequency dependent impedances
- Stability is assessed by analyzing the loop gain $G_o(s)$ of the system

$$I(s) = \left[I_{WTC}(s) - \frac{V_{MMC}(s)}{Z_{WTC}(s)} \right] \frac{1}{1 + \frac{Z_{MMC}(s)}{Z_{WTC}(s)}}$$

- System is stable if $G_o(s) = \frac{Z_{MMC}(s)}{Z_{WTC}(s)}$ satisfies Nyquist stability criterion



Characterisation of real converter behaviour is required
→ Impedance Measurement

Impedance Measurement Overview


Objectives:

- Assess characteristic of active components without opening the “blackbox” → OEM IP
- Validation of the methods


Method:

- Impedance derived by injecting perturbation voltages or currents (freq. sweep)
- Impedance measurement for:
 - Hardware WTC (full-scale) and MMC (small-scale)
 - Converter Controller + real-time simulation
 - Comparison

Flexible Power Grid Lab @ DNV GL



MMC Test Bench @ RWTH Aachen



Impedance Measurement

Wind Turbine Converters/Controllers

Achievements:

- ✓ Development and validation of a impedance measure setup at DNV GL in Arnhem
 - MW-scale converter
 - Control replicas
- ✓ Input-impedance measurement of a commercial 1 MW wind turbine converter from Ming Yang Smart Energy, China
- ✓ Input-impedance measurement of the corresponding control replica

Flexible Power Grid Lab @ DNV GL


Harmonic injection
200 kW - PA



Real
Wind Turbine
Converter (T4)



AC Grid Emulator



DUT (1 MW)


Impedance Measurement

Wind Turbine Converters/Controllers

Achievements:

- ✓ Development and validation of a impedance measure setup at DNV GL in Arnhem
 - MW-scale converter
 - Control replicas
- ✓ Input-impedance measurement of a commercial 1 MW wind turbine converter from Ming Yang Smart Energy, China
- ✓ Input-impedance measurement of the corresponding control replica

Flexible Power Grid Lab @ DNV GL





Impedance Measurement

Wind Turbine Converters/Controllers


Results:

- ✓ Current perturbation method is feasible for the input-impedance measurement
 - ✓ Input-impedance measurement of a commercial 1 MW converter
 - ✓ Good matching between the hardware and control replica approach in the low to medium frequency range
- For frequencies above 1500 Hz:
 - Higher impact of measurement noises
 - Current perturbation through damped by decoupling transformer


Impedance Measurement of Z_{dd}



MMC Test Bench Overview



AC system and component modelling



Source: www.windpoweroffshore.com

- OP5707 real-time simulator for AC grids (up to 3000 nodes) and wind farms
- OP4510 real-time simulator as DC grid controller
- 4x Puissance Plus power amplifiers (21 kVA, 4-Q operation, -3 dB at 50 kHz)


MMC converter stations



Source: ABB

- Hardware representation of Modular Multilevel Converters with half-/full-bridge submodules (10 levels per converter arm) at laboratory scale: $V_{dc,r} = 400 \text{ V}$, $I_{dc,r} = 15 \text{ A}$
- Possibility to investigate DC grids with up to 8 converter stations in sym. monopole or up to 4 converter stations in bipolar configuration

DC-line models



Source: www.offshore-technology.com

- 32x Pi-Line models
- Up to 800 km in bipolar grid configuration
- Up to 1,600 km in monopolar grid configuration
- Different DC topologies can be represented with hardware components at laboratory scale

MMC Test Bench



Status Update

Achievements:

- ✓ Good matching between MMC Test Bench and Simulations (dynamic studies → Steps and setpoint changes)
- ✓ PHiL with (strong) transmission grids and wind power plant
- ✓ Impedance measurements in grid following operation
- ✓ “Online” impedance evaluation on the FPGAs of the real-time simulator to avoid “heavy” post-processing

Next Steps:

- Investigation of PHiL operation for wind power plants in grid forming control
- Impedance measurement of the MMCs in grid forming control
- Impact and DC faults on Wind Turbine Controls



Impedance Measurement


MMC Test Bench

Comparison between


- Full-scale simulation (1.2 GW – 400 kV_{RMS,LL})
- Lab-scale simulation (6 kW – 400 V_{RMS,LL})
- Lab-scale HVDC Converter (6 kW – 400 V_{RMS,LL})
- *Scaling between full-scale and small-scale is not yet integrated in this figure*

HVDC Converter Set-point


- P-control mode
- $P_{ac}^* = 0.5 \text{ p.u.} / Q_{ac}^* = 0.0 \text{ p.u.}$



Positive Sequence Impedance



Negative Sequence Impedance



HVDC / WT Control-Hardware-in-the-Loop

@ DNV GL, Arnhem


VBC – Valve Base Control
PCP – Pole Control & Protection

↔ Digital signals
↔ Analog signals

- ✓ Real-time Replica with commercial WT and HVDC converter controllers
- ✓ HVDC and WT Converter represented with detailed real-time simulation

Harmonic Resonance Analysis:


- Impedance model of a commercial HVDC MMC controller
- Time-domain validation of the results obtained in frequency domain



Impedance-based Stability Criterion

Achievements & Conclusions

- ✓ Development of test circuits and setups for impedance measurement
- ✓ Blackbox impedance measurement of WT converters and HVDC MMC
- Comparison of impedance measurements physical converters and their simulation replicas (with real controllers)
 - Good matching for low to medium frequencies
 - Deviations at higher frequencies





Any Questions?



UNIVERSIDAD
POLITECNICA
DE VALENCIA



APPENDIX

DISCLAIMER & PARTNERS

COPYRIGHT

PROMOTioN – Progress on Meshed HVDC Offshore Transmission Networks
MAIL info@promotion-offshore.net WEB www.promotion-offshore.net

The opinions in this presentation are those of the author and do not commit in any way the European Commission

PROJECT COORDINATOR

DNV GL Netherlands B.V.
Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
Tel +31 26 3 56 9111
Web www.dnvgl.com/energy

CONTACT

Philipp Ruffing
Work package 16 leader
ruffing@ifht.rwth-aachen.de

PARTNERS

DNV GL Netherlands B.V., ABB AB, KU Leuven, KTH Royal Institute of Technology, EirGrid plc, SuperGrid Institute, Deutsche WindGuard GmbH, Mitsubishi Electric Europe B.V., Affärsverket Svenska kraftnät, Alstom Grid UK Ltd (Trading as GE Grid Solutions), University of Aberdeen, Réseau de Transport d'Électricité, Technische Universiteit Delft, Statoil ASA, TenneT TSO B.V., Stiftung OFFSHORE-WINDENERGIE, Siemens AG, Danmarks Tekniske Universitet, Rheinisch-Westfälische Technische Hochschule Aachen, Universitat Politècnica de València, SCiBreak AB, Forschungsgemeinschaft für Elektrische Anlagen und Stromwirtschaft e.V., Ørsted Wind Power A/S, The Carbon Trust, Tractebel Engineering S.A., European University Institute, Iberdrola Renovables Energía, S.A., European Association of the Electricity Transmission & Distribution Equipment and Services Industry, University of Strathclyde, ADWEN Offshore, S.L., Prysmian, Rijksuniversiteit Groningen, MHI Vestas Offshore Wind AS, Energinet.dk, Scottish Hydro Electric Transmission plc, SCiBreak AB

