

Frequency domain based DC fault analysis for bipolar HVDC grids

Mian WANG¹ , Jef BEERTEN¹, Dirk Van HERTEM¹



Abstract This paper proposes a frequency domain based methodology to analyse the influence of High Voltage Direct Current (HVDC) configurations and system parameters on the travelling wave behaviour during a DC fault. The method allows us to gain deeper understanding of these influencing parameters. In the literature, the majority of DC protection algorithms essentially use the first travelling waves initiated by a DC fault for fault discrimination due to the stringent time constraint in DC grid protection. However, most protection algorithms up to now have been designed based on extensive time domain simulations using one specific test system. Therefore, general applicability or adaptability to different configurations and system changes is not by default ensured, and it is difficult to gain in-depth understanding of the influencing parameters through time domain simulations. In order to analyse the first travelling wave for meshed HVDC grids, voltage and current wave transfer functions with respect to the incident voltage wave are derived adopting Laplace domain based component models. The step responses obtained from the voltage transfer functions are validated

by comparison against simulations using a detailed model implemented in PSCADTM. Then, the influences of system parameters such as the number of parallel branches, HVDC grid configurations and groundings on the first travelling wave are investigated by analysing the voltage and current transfer functions.

Keywords HVDC grids, DC grid protection, Travelling wave, Frequency domain analysis, Transfer function

1 Introduction

Voltage Source Converter (VSC) based High Voltage Direct Current (HVDC) grids are expected to play an important role in the development of the future European power system, especially in interconnecting large-scale offshore wind farms and facilitating an integrated European energy market [1]. DC protection system is the one of the key factors in order to build a reliable HVDC grid. Compared to the conventional AC protection system, the DC protection system has particular challenges because of the high rate of rise of the fault current, which results in very stringent time constraints on the DC protection system. In meshed HVDC grids, the total time for the entire fault clearing process using selective protection strategy is considered in the order of several milliseconds which is one order of magnitude below the operating time of AC protection systems [2].

In order to achieve fast and selective protection in HVDC grids, HVDC circuit breakers and selective fault detection relays are necessary. Although HVDC circuit breakers are not commercially available yet, the development of several HVDC circuit breaker prototypes indicates that interrupting DC currents in the order of kA can be

CrossCheck date: 20 June 2016

Received: 19 May 2017 / Accepted: 20 June 2017

© The Author(s) 2017. This article is an open access publication

✉ Mian WANG
mian.wang@kuleuven.be

Jef BEERTEN
jef.beerten@kuleuven.be

Dirk Van HERTEM
dirk.vanhertem@kuleuven.be

¹ EnergyVille/Electa Research Group, Electrical Engineering Department ESAT, KU Leuven, 3001 Heverlee, Belgium

achieved in just few milliseconds [3–5]. In the literature, most research on DC protection has focused on developing fast and selective DC protection algorithms, which can be categorized into unit protection [6, 7] and non-unit protection [8–12]. Current differential and travelling wave differential algorithms are proposed in [6, 7], respectively, where the first travelling waves are used to distinguish the faulted cable. Non-unit protection algorithms use series inductors at the line terminals to define protection zones, and essentially identify the fault by using information contained in the first voltage/current waves. Due to the reflection by the series inductor at the cable terminal, the first voltage waves at the faulted terminals have distinctive waveforms compared to those at the healthy terminals, and can thus be used for fault discrimination. Although the input signals and discrimination methods of these protection algorithms are different, all algorithms essentially use fault initiated travelling waves to discriminate the faulted line. Therefore, in-depth understanding of the travelling wave behaviour is essential for designing robust DC protection algorithms.

Most proposed protection algorithms, however, have been designed based on extensive time domain simulations for one configuration or test system. Therefore, general applicability or adaptability to different configurations and system changes is not by default ensured. Moreover it is difficult to gain in-depth understanding of the influencing parameters through time domain simulations. Additionally, the future HVDC grids can be developed into monopolar, bipolar, or more complex configurations, such as a bipolar backbone with monopolar tapplings [13–15]. Such a complex future system might have various grounding schemes, such as low impedance grounding or ungrounded stations. The grounding points and the number of parallel branches connected to a busbar in a meshed HVDC grid may change due to system reconfiguration, maintenance, or outage. Furthermore, the inductors in series with the DC circuit breakers fundamentally influence the travelling wave behaviour, and the size of these inductors might take various values depending on the requirements from the DC circuit breakers [3, 4] and DC grids [16]. However, protection settings are preferred to be insensitive to changes in the system conditions. Therefore, the influence of these changes on the travelling wave behaviour needs to be studied properly. A Laplace domain-based grid modelling [9] allows to systematically study such effects. This paper builds on this travelling wave-based approach to study fault behaviour in bipolar, asymmetrical and symmetrical monopolar systems. In doing so, the paper provides the guidelines needed for the design of multivendor protection algorithms.

The paper is arranged as follows. First, voltage and current wave transfer functions with respect to the incident

voltage wave are derived for meshed bipolar HVDC grids. Second, the frequency domain based model is validated against time domain simulation using a detailed model implemented in PSCADTM. Third, the induced voltages and currents by the incident voltage wave on the positive and negative poles are analysed in order to understand the degree of the mutual coupling between the two poles. Fourth, the influences of system changes such as number of parallel branches, grounding impedances and series inductors on the travelling waves are analysed for a bipolar HVDC grid. Finally, the influences of different HVDC configurations and grounding schemes are investigated.

2 Travelling waves in bipolar HVDC grids

In meshed HVDC grids, the DC fault clearing should typically be achieved in the order of few milliseconds; therefore, selective fault detection and discrimination typically has to be achieved within 1 ms after the fault reaching the relay [9–11]. During this time frame, the fault behaviour is dominated by the travelling wave phenomenon. For long cable lengths, reflected waves at the remote stations are outside the time frame of interest (e.g. cable length > 75 km) and the analysis can be limited only to the first reflection of the incident wave [9]. For DC faults along the cable, the first voltage wave front contains the most important information for fault detection and discrimination. This paper therefore only focuses on the analysis of the first reflection and transmission of the incident wave arriving at a converter station.

The converter station under study can be expressed as shown in Fig. 1, where the measurement relays are placed between the cable terminals and the series inductors. The




Fig. 1 Travelling waves at a bipolar converter station with a fault at point F

voltages and currents at the relay positions are typically used for fault identification and are thus of interest for the analysis. e_i is the incident voltage wave arriving at the relay position of the faulted cable, and e_r is the reflected voltage wave at this point. The resulting voltage and current are (e_0, i_0) . The voltage and current transmitted to the adjacent cables in the positive pole and to the cables in the negative pole are denoted as (e_{pk}, i_{pk}) and (e_{nk}, i_{nk}) , respectively. The number of cables connected to the positive, neutral and negative polarity terminals of the converters are N_p, N_m and N_n , respectively. The number of cables in each pole can be different considering maintenance, outage, or an asymmetric configuration. The characteristic impedance of the cables are denoted as $Z_{Cp1}(s), \dots, Z_{CpNp}(s), Z_{Cm1}(s), \dots, Z_{CmNm}(s)$ and $Z_{Cn1}(s), \dots, Z_{CnNn}(s)$, respectively. L_{p1}, \dots, L_{pNp} and L_{n1}, \dots, L_{nNn} are the series inductors of the DC circuit breakers in the positive and negative poles. $Z_{conv}(s)$ is the equivalent impedance of the converters. The grounding impedance is represented by $Z_g(s)$, which could be infinite if the converter station is ungrounded, resistive, inductive or zero depending on the grounding scheme.

2.1 Travelling wave transfer functions

The surge impedance of each portion, looking from the position of the measurement relay at the faulted cable, is denoted in Fig. 1 for the purpose of deriving travelling wave transfer functions. The surge impedances of the parallel branches of the positive (excluding the faulted cable), neutral and negative poles, $Z_p(s), Z_m(s)$ and $Z_n(s)$, are

$$\begin{cases} Z_p(s) = (sL_{p2} + Z_{Cp2}(s)) // \dots // (sL_{pNp} + Z_{CpNp}(s)) \\ Z_m(s) = Z_{Cm1}(s) // \dots // Z_{CmNm}(s) \\ Z_n(s) = (sL_{n1} + Z_{Cn1}(s)) // \dots // (sL_{nNn} + Z_{CnNn}(s)) \end{cases} \quad (1)$$

Using basic circuit theory, the surge impedances of the noted four portions in Fig. 1 $Z_j(s), j = 1, 2, \dots, 4$ are

$$\begin{cases} Z_1(s) = Z_p(s) // Z_2(s) \\ Z_2(s) = Z_{conv}(s) + Z_3(s) \\ Z_3(s) = Z_m(s) // Z_g(s) // Z_4(s) \\ Z_4(s) = Z_{conv}(s) + Z_n(s) \end{cases} \quad (2)$$

Then, the total surge impedance seen by the faulted cable at its terminal, $Z_0(s)$ is

$$Z_0(s) = sL_{p1} + Z_1(s) \quad (3)$$

The resulting voltage and current $(e_0(s), i_0(s))$ at the relay position are now a function of the incident voltage wave

$$\begin{cases} e_0(s) = \frac{2Z_0(s)}{Z_0(s) + Z_{Cp1}(s)} \cdot e_i(s) \\ i_0(s) = \frac{2}{Z_0(s) + Z_{Cp1}(s)} \cdot e_i(s) \end{cases} \quad (4)$$

and the voltage and current transmitted to the adjacent cables $(e_{pk}(s), i_{pk}(s))$ are given by

$$\begin{cases} e_{pk}(s) = \frac{Z_{Cpk}(s)}{sL_{pk} + Z_{Cpk}(s)} \cdot Z_1(s) \cdot i_0(s) \\ i_{pk}(s) = \frac{e_{pk}(s)}{Z_{Cpk}(s)}, \quad k = 2, 3, \dots, N_p \end{cases} \quad (5)$$

Similarly, the voltage and current transmitted to the cables in the negative pole $(e_{nk}(s), i_{nk}(s))$ are given by

$$\begin{cases} e_{nk}(s) = \frac{Z_{Cnk}(s)}{sL_{nk} + Z_{Cnk}(s)} \cdot \frac{Z_n(s)}{Z_4(s)} \cdot \frac{Z_3(s)}{Z_2(s)} \cdot Z_1(s) \cdot i_0(s) \\ i_{nk}(s) = \frac{e_{nk}(s)}{Z_{Cnk}(s)}, \quad k = 1, 2, \dots, N_n \end{cases} \quad (6)$$

The voltage and current transfer functions are defined with respect to the incident voltage wave $e_i(s)$ as

$$\begin{cases} G_j(s) = \frac{e_j(s)}{e_i(s)} \\ H_j(s) = \frac{i_j(s)}{e_i(s)} \end{cases} \quad (7)$$

where $j = \{0, pk, nk\}$ for the faulted cable, adjacent cables of the positive pole and cables of the negative pole, respectively.

The voltage and current transfer functions can be obtained by dividing (4), (5) and (6) by $e_i(s)$. For the faulted cable terminal,

$$\begin{cases} G_0(s) = \frac{2Z_0(s)}{Z_0(s) + Z_{Cp1}(s)} \\ H_0(s) = G_0(s) / Z_0(s) \end{cases} \quad (8)$$

and for the adjacent cables in the positive pole,

$$\begin{cases} G_{pk}(s) = \frac{2Z_{Cpk}(s)Z_1(s)}{(sL_{pk} + Z_{Cpk}(s))(Z_0(s) + Z_{Cp1}(s))} \\ H_{pk}(s) = G_{pk}(s) / Z_{Cpk}(s) \end{cases} \quad (9)$$

where $k = 2, 3, \dots, N_p$.

Similarly, the voltage and current transfer functions for the cables in the negative pole are given by

$$\begin{cases} G_{nk}(s) = \frac{2Z_{Cnk}(s)Z_n(s)Z_3(s)Z_1(s)}{(sL_{nk} + Z_{Cnk}(s))Z_4(s)Z_2(s)(Z_0(s) + Z_{Cp1}(s))} \\ H_{nk}(s) = G_{nk}(s) / Z_{Cnk}(s) \end{cases} \quad (10)$$

where $k = 1, 2, \dots, N_n$.

2.2 Frequency domain component models

This section describes the frequency domain models of the components used in this paper.

2.2.1 Cable characteristic impedance

Distributed parameter frequency dependant models of transmission lines are used to describe the voltage and current travelling waves along transmission lines. In such a representation, a transmission line is characterized by two matrix transfer functions: the propagation matrix \mathbf{H} and the characteristic impedance matrix $\mathbf{Z}_C(s)$. The frequency dependency of these matrices can be approximated using rational functions in the frequency domain [17].

$$f(s) = d + s \cdot h + \sum_{i=1}^N \frac{c_i}{s - a_i} \quad (11)$$

where, c_i are the residues, a_i are the poles, d , h are real constants, and N is the approximation order.

In this paper, the parameters for the cable geometry and materials are taken from [18]. The parameters in (11) are obtained via the PSCADTM Line Constants Program [19]. Only the diagonal elements of the characteristic impedance and propagation matrices are used in the study considering that mutual impedances between cables are relatively small [20]. All the cables are assumed to have the same characteristic impedance in this paper. Note that in practical systems, the conductor and the insulating layer of the metallic return cables can have smaller diameters compared to those of the main cables due to lower requirements on the return cables.

2.2.2 Equivalent impedance of MMC converters

The converter topology considered in this study is half-bridge based modular multilevel converter (HB-MMC). The behaviour of a HB-MMC during a DC fault can be divided into capacitive discharge stage and diode rectifier stage starting after blocking the Insulated Gate Bipolar Transistors (IGBTs) [21]. In the first milliseconds after a DC fault before blocking the IGBTs, only the capacitive discharge stage needs to be taken into account. The HB-MMC converter is modelled by an equivalent RLC circuit in line with the model from [21]. The capacitive discharge of the submodules is approximated by an equivalent capacitance which is equal to the total capacitance of the inserted submodules prior to the arrival of the fault wave.

$$Z_{conv}(s) = sL_{eq} + R_{eq} + \frac{1}{sC_{eq}} \quad (12)$$

where L_{eq} , R_{eq} and C_{eq} are the equivalent inductance, resistance and capacitance.

In order to validate the RLC representation of the MMC converter, a comparison between the frequency response of the RLC equivalent model and the simulated impedance responses is given in Fig. 2. Main parameters of the converter model, taken from [22] are given in Table 1. The simulated impedance response are calculated using frequency sweeping on a continuous MMC model implemented in PSCADTM [18]. Figure 2 shows that first, the operating point of the converter influences the converter impedance in the low frequency region. Second, the RLC equivalent model matches with the simulated impedances in the high frequency region very well. Since the time range concerned in this study is only the first millisecond, the RLC model is considered to have sufficient accuracy.

3 Evaluation against PSCADTM models

In this section, the frequency domain model is validated by comparing the step response of the transfer function with time domain simulations based on detailed models implemented in PSCADTM. A four terminal bipolar test system in Fig. 3 adapted from the symmetric monopolar grid [18] is used to perform the comparison. Main parameters of the test system are given in Table 2. Mutually coupled distributed parameter frequency dependent cable models are used in the simulation. The cable parameters and configurations are given in Table A1 and Fig. A1 in the ‘‘Appendix A’’. Both pole-to-ground and




Fig. 2 Comparison of the equivalent impedance of the MMC converter between the RLC model and frequency-sweep in PSCADTM

Table 1 Converter parameters (rating: 500 MVA)

Converter parameters	Values
Arm capacitance C_{arm}	65.1 μ F
Arm inductance L_{arm}	38.2 mH
Arm resistance R_{arm}	0.4 Ω




Fig. 3 A four terminal bipolar test system used in PSCAD™ simulations

Table 2 Grid parameters and simulation conditions

Grid parameters	Values
Rated power	500 MVA
DC voltage	\pm 320 kV
AC grid voltage	400 kV
AC converter voltage	185 kV
Bus filter reactor	0 mH
Return path	metallic return
Grounding	solidly grounded at converter station 1
Simulation conditions	Values
Fault type	pole-to-ground pole-to-pole
Fault location	25 km, 50 km, ..., 200 km from Bus 1
Series line inductor	50 mH and 100 mH

pole-to-pole fault at 8 fault locations along cable L13 are simulated. Two values of the series line inductors 50 mH and 100 mH are used.

Figure 4 shows the calculated and simulated voltages $e_0(t)$ at the cable terminal for pole-to-ground faults applied at 25, 100 and 200 km from Bus 1. It is shown that the calculated response corresponds well with the simulated waveforms for the first reflection. This validates




Fig. 4 Comparison between calculated step responses and PSCAD™ simulations (F1, F4 and F8 are cable L13 faults located 25, 100 and 200 km from Bus 1; Cal are calculated from transfer function; Sim are simulation results from PSCAD™)




Fig. 5 Maximum differences between calculated step responses and PSCAD™ simulations (ptg: pole-to-ground faults, ptp: pole-to-pole faults)

that neglecting mutual coupling of the cables in the transfer function is acceptable. The difference between the calculated and the simulated response using a detailed converter model diverges more for a longer period of time. This difference is due to the fact that the RLC representation of a converter is mainly accurate in the high frequency region. The evaluation window of the maximum difference is taken as the time window of the first reflection up to 1 ms. As shown in Fig. 5, the maximum difference is larger for remote faults, mainly because the evaluation window is longer for remote faults. Nevertheless, the maximum difference within the first reflection is 0.038 p.u. at 320 kV base, which verifies that frequency domain based transfer function provides a valid representation for the first travelling wave behaviour with good accuracy.

4 Mutual coupling in bipolar HVDC links

In a bipolar configuration, it is important to understand to what extent the fault behaviour in one pole influences the other pole. In this study, frequency and step responses of the voltage and current transfer functions are used to investigate the mutual coupling of the two poles.






Fig. 6 Frequency responses of voltage and current transfer functions (color indicates transfer functions while line styles—solid, dotted, densely dashed, dashdotted and loosely dashed—indicate the size of the inductor)

The bode magnitude plots of the voltage and current transfer functions in (8) and (10) are shown in Fig. 6 assuming a point-to-point bipolar link (N_p , N_m , and $N_n = 1$). The converter station is assumed to be ungrounded considering that if the converter station is low-impedance or solidly grounded, the influence on the negative pole is insignificant or non-existent. Figure 6 gives the bode plots of the transfer functions in absolute magnitude. Figure 7 gives the step responses of the transfer functions up to 1 ms. Since a DC fault initiated incident voltage wave approximates a step change, the step responses of the transfer functions are corresponding to time domain simulations of DC faults at the cable terminal.

Figure 6a shows that $G_0(s)$, the transfer function of the resulting voltage at the faulted cable, has the characteristic of a band-rejection filter. The gain of the high frequency region for all series inductor values is approximately 2, which means the high-frequency components of the incident wave are doubled, i.e. totally reflected at the faulted cable terminal. The resonant frequency of this equivalent band-rejection filter is largely determined by the series resonance of the equivalent converter capacitance C_{eq} and by the sum of the equivalent converter inductance and the series inductor $L_{eq} + L_{p1}$. A large series inductor shifts the resonant frequency to lower frequencies. Besides, it also reduces the bandwidth of the rejection range, which results in reflecting more low frequency components. As shown in Fig. 6a, the upper cut-off frequency shifts from approximately 10^4 Hz to 10^2 Hz when the series inductor increases




Fig. 7 Step responses of voltage and current transfer functions (color indicates step responses while line styles—solid, dotted, densely dashed, dashdotted and loosely dashed—indicate the size of the inductor)

from 0 mH to 300 mH. Figure 7a shows the step responses of $G_0(s)$, which have a initial magnitude of 2 corresponding to total reflection of the high frequency components. The step response of $G_0(s)$ with a small series inductor decays much faster as more frequency components are located in the bandwidth of the rejection range.

As shown in Fig. 6b, $H_0(s)$, the resulting current transfer function at the faulted cable terminal, has the characteristic of a band-pass filter. Since $H_0(s)$ is defined with respect to the incident voltage wave, it can be considered as an admittance which describes the relationship between the resulting current at the faulted cable terminal and the incident voltage. This admittance is highly inductive due to the presence of the series inductor and the converter arm inductors. Consequently, high-frequency components of the incident voltage are largely attenuated. In the low frequency region, this admittance is highly capacitive, mainly due to the equivalent converter capacitor. As a result, low-frequency components of the incident voltage are also largely attenuated. The bandwidth and gain of the frequency response of $H_0(s)$ increase as the series inductors decrease.

$G_{nk}(s)$ and $H_{nk}(s)$, the voltage and current transfer functions at the negative pole, also have characteristics of band-pass filters, as shown in Fig. 6a, b. The high-frequency components of the incident wave are well damped, and the larger the series inductor, the smaller the bandwidth becomes. Moreover, even without the series inductor, high-frequency components still can not pass to the

negative pole because the inductive behaviour of the converter. This can also be confirmed by the step responses of $G_{nk}(s)$ and $H_{nk}(s)$ in Fig. 7, which have much smaller amplitudes compared to those of $G_0(s)$ and $H_0(s)$. Therefore, in terms of very fast transients in the first millisecond, the mutual coupling between the two poles of a cable-based bipolar system is found to be insignificant.

5 Influences of system changes on travelling waves in meshed bipolar HVDC grids

This section analyses the influence of system changes on the travelling waves in meshed bipolar HVDC grids. The considered parameters are the number of the parallel branches in the positive pole, the grounding impedance and the series inductor value.

5.1 Number of parallel branches

The number of the branches in the positive pole N_p is varied from 1 to 4, while the total numbers of the parallel branches in the neutral and negative poles, N_m and N_n are fixed at 4. The frequency and step responses of $G_0(s)$ and $G_{pk}(s)$ are shown in Figs. 8 and 9 respectively for different number of parallel branches N_p and different values of the series inductors L .

Figure 8a, b shows that if the series inductor is zero, the voltages at the faulted and healthy cables are exactly the same since the cables are connected to the same electrical point. The gain of $G_0(s)$ and $G_{pk}(s)$ in the low and high frequency regions is approximately equal to $\frac{2}{N_p}$, with $N_p > 2$ considering $Z_{conv}(s) \gg Z_C(s)$ in both the low and high frequency region.

As shown in Fig. 8b, $G_{pk}(s)$, the voltage transfer function of the adjacent cables has a more complex behaviour in the case that series inductors are present. The size of the series inductor changes both the shape and the cut-off frequency, beyond which $G_{pk}(s)$ has a gain close to 0. Furthermore, large series inductors reduce the cut-off frequency of the frequency responses. The influence of the number of the parallel branches is more pronounced in the low-frequency region, where the cable characteristic impedance is more dominant compared to the influence of the series inductors. The step responses in Fig. 9b also give an indication of the margins, in terms of both time and voltage level, to discriminate the faulted cable from the adjacent ones. For instance, as shown in Fig. 9a, b fault discrimination will only have about 0.2 ms for a series inductor of 10 mH if voltage level is used for discrimination, whereas large inductors allow more time and larger margins to discriminate the faulted cable.




Fig. 8 Influence of number of parallel branches: frequency responses of voltage transfer functions (color indicates the number of parallel branches while line styles—solid, dotted, dashed and dashdotted—indicate the size of the inductor)




Fig. 9 Influence of number of parallel branches: step responses of voltage transfer functions (color indicates the number of parallel branches while line styles—solid, dotted, dashed and dashdotted—indicate the size of the inductor)

5.2 Grounding impedance

Bipolar HVDC systems are typically solidly or low-impedance grounded and it can be expected such groundings also in VSC-HVDC [13]. However, a converter station can be grounded or ungrounded depending on the operation conditions. The grounding options considered in this section are solid grounding




Fig. 10 Influence of grounding scheme: frequency responses of the voltage transfer function $G_0(s)$ (color indicates grounding impedances while line styles—solid, dotted, dashed and dashdotted—indicate the size of the inductor)

($Z_g(s) = 0 \Omega$), resistance grounding ($Z_g(s) = 10 \Omega$), inductance grounding of 50 mH ($Z_g(s) = 0.05 s$) and ungrounded ($Z_g(s) = \infty$). The total number of the parallel branches in all three layers, N_p, N_m and N_n is chosen equal to 3.

Figures 10 and 11 show the frequency and step responses of $G_0(s)$ for different grounding impedances and series inductances. It can be seen that the grounding impedance has an insignificant influence on the frequency response and only modifies the frequency response near the resonant frequency region, which corresponds to the series LC resonance of the converter. In both low and high-frequency region, the large impedance of the converter blocks the influence of any changes in the neutral and negative pole. The step responses shown in Fig. 11 confirms the analysis in the frequency-domain.

6 Influences of HVDC configurations with different grounding schemes

As future HVDC grids can have more complex configurations with mixed bipolar and monopolar configurations, the influences of HVDC configurations with different grounding schemes on the travelling wave are investigated in this section. The impact of HVDC configurations with different groundings is evaluated by




Fig. 11 Influence of grounding scheme: step responses of the voltage transfer function $G_0(s)$ (color indicates grounding impedances while line styles—solid, dotted, dashed and dashdotted—indicate the size of the inductor)

comparing the voltage transfer functions with that of a solidly grounded bipolar configuration.

Figure 12 shows the asymmetrical and symmetrical monopolar configurations for a converter station. The voltage transfer functions at the faulted cable terminal have the same form as (8), while the total surge impedance seen by the faulted cable are $Z_0^{Asym}(s)$ and $Z_0^{Sym}(s)$.

$$\begin{cases} Z_0^{Asym}(s) = sL_{p1} + Z_p(s) \parallel [Z_{conv}(s) + Z_3^{Asym}(s)] \\ Z_0^{Sym}(s) = sL_{p1} + Z_p(s) \parallel [Z_{conv}(s) + Z_3^{Sym}(s)] \end{cases} \quad (13)$$

Obviously, only the equivalent impedance of the neutral and negative poles, denoted as $Z_3(s)$, differs depending on HVDC system configurations and their grounding schemes. As shown in (13), $Z_3(s)$ is in series with the converter surge impedance $Z_{conv}(s)$; therefore, a comparison between $Z_{conv}(s)$ and $Z_3(s)$ is performed to analyse the impact of HVDC configurations with different groundings. The number of the parallel branches and the series inductors are chosen equal to 3 and 50 mH, respectively. The grounding impedances are set the same as in Sect. 5.2, respectively.

A summary of $Z_3(s)$ for different configurations and groundings is given in Table 3. It is obvious that the total surge impedances are the same for solidly grounded asymmetrical monopolar and bipolar configurations regardless of return paths. Therefore, the voltage/current transfer functions are the same in these configurations. Figure 13 shows that the configurations can




Fig. 12 Travelling waves at a converter station

Table 3 $Z_3(s)$ for different configurations and groundings

Config.	Return (Symbol)	Grounding	$Z_3(s)$
Asym.	Earth (Asym _{GR})	solid	0
		impedance	$Z_g(s)$
	Metallic (Asym _{MR})	solid	0
		ungrounded	$Z_m(s)$
		impedance	$Z_m(s) // Z_g(s)$
		impedance	$Z_m(s) // (Z_{conv}(s) + Z_n(s))$
Bipole	Earth (Bi _{GR})	solid	0
		impedance	$Z_g(s) // (Z_{conv}(s) + Z_n(s))$
	Metallic (Bi _{MR})	solid	0
		ungrounded	$Z_m(s) // (Z_{conv}(s) + Z_n(s))$
		impedance	$Z_m(s) // (Z_{conv}(s) + Z_n(s)) // Z_g(s)$
		impedance	$Z_n(s)$




Fig. 13 Comparison between $Z_{conv}(s)$ and $Z_3(s)$ of different configurations, $L = 50$ mH

largely be divided into two groups, the first group (Grp_I), where $Z_3(s)$ is negligible compared to $Z_{conv}(s)$ in the high frequency region ($f > 10^2$ Hz) and the second group (Grp_{II}), where $Z_3(s)$ is comparable to $Z_{conv}(s)$ in the high frequency region.

The differences of the step responses between each configuration and the solidly grounded bipolar configuration are defined by

$$\Delta g(t) = \mathcal{L}^{-1} \left\{ \frac{G_{0,x}(s) - G_{0,grded}(s)}{s} \right\} \quad (14)$$


where x represents configurations listed in Table 3.

For asymmetrical and symmetrical monopolar configurations, two converter dimensions are considered in the comparison. One is the same dimension as the bipolar configuration, 500 MVA per converter, for the purpose of comparing the influence of HVDC configurations and grounding. The other is 900 MVA in Table 4, which is more realistic sizing of existing offshore links.


Frequency responses of $G_0(s)$ under different configurations and groundings are shown in Fig. 14. The symbols used to represent the configurations in Fig. 14 are listed in Table 3.

Table 4 Converter parameters (rating: 900 MVA [18])

Converter parameters	Values
Arm capacitance C_{arm}	29.3 μ F
Arm inductance L_{arm}	84.8 mH
Arm resistance R_{arm}	0.885 Ω



(a) Voltage transfer functions with converters rated at 500 MVA



(b) Voltage transfer functions with converters rated at 900 MVA

- Bi_{GR}/MR $Z_g(s) = 0\Omega$; ■ Sym
- Bi_{GR} $Z_g(s) = 10\Omega$; ■ Bi_{GR} $Z_g(s) = 0.05s$
- ASYM_{MR} $Z_g(s) = 10\Omega$; ■ ASYM_{MR} $Z_g(s) = 0.05s$
- ASYM_{GR} $Z_g(s) = 10\Omega$; ■ ASYM_{GR} $Z_g(s) = 0.05s$
- ASYM_{MR} $Z_g(s) = \infty\Omega$

L : — 10 mH; - - - 100 mH

Fig. 14 Influence of configuration and grounding: frequency responses of voltage transfer functions $G_0(s)$, N_p, N_m , and $N_n = 3$ (color indicates HVDC configuration and grounding schemes while line styles—solid, and dashdotted—indicate the size of the inductor)




Fig. 15 Influence of configuration and grounding: step response differences compared to solidly grounded asymmetric monopolar/bipolar system with 500 MVA converter $\Delta g(t)$, N_p, N_m , and $N_n = 3$ (color indicates HVDC configuration and grounding schemes while line styles—solid, and dashdotted—indicate the size of the inductor)

Figure 15 shows $\Delta g(t)$, the differences of the step responses between each configuration and the solidly grounded bipolar configuration with converter dimension rated at 500 MVA. As shown in Fig. 15a, for the same converter dimension, these differences of Gr_{pII} cannot be neglected, especially for small series inductors. On the contrary, the differences of Gr_{pI} are less than 0.2 % up to 0.2 ms, even with series inductors of 10 mH. In the cases using a 900 MVA converter, the differences of both groups with respect to the reference case are slightly larger than those of the cases with the same converter size. In terms of fast transients, Gr_{pI} and Gr_{pII} can be considered as effectively low and high impedance grounded, respectively. The behaviour of the travelling waves of Gr_{pI} is comparable to that of a solidly grounded bipolar configuration, while the fast transient behaviour of Gr_{pII} is only comparable to that of a solidly grounded bipolar configuration when the series inductors are large.

7 Conclusion

In this paper, a frequency-domain based methodology to analyse the travelling wave behaviour in meshed HVDC grids has been proposed. A comparison of the step response

calculated using transfer function and time domain simulation using a detailed model in PSCADTM verified that frequency domain based transfer function provides a valid representation for the first travelling wave behaviour with good accuracy. By analysing the frequency responses of the voltage/current transfer functions with respect to the incident voltage wave, the influences of the system parameters on the first travelling waves can be accurately predicted without the need for performing extensive time domain simulations.

The proposed methodology is used to analyse the travelling waves in a bipolar configuration with metallic return. First, the mutual coupling, in terms of very fast transient between the two poles is shown to be insignificant. Second, the influence of the number of the parallel branches in the same pole, is shown to be more pronounced in the low-frequency region, which implies that very fast transients are less influenced by the number of the parallel branches. Third, the series inductor at the cable terminal plays vital role in primary protection algorithms based on local measurements. Large series inductors give large margin in both voltage detection level and the time to identify the faulted cable. Fourth, the grounding impedances in a bipolar system have insignificant influences on the first travelling wave.

In addition, the travelling wave behaviours under different HVDC configurations and groundings have been analysed. Among the configurations considered in this study, both asymmetrical monopolar/bipolar configuration with metallic returns regardless of grounding and low resistive-grounded/solidly grounded asymmetrical monopolar/bipolar configuration with ground return are effectively low-impedance grounded in terms of fast transients. Symmetrical monopolar configuration and inductive-grounded asymmetrical monopolar/bipolar configuration with ground return can be considered as effectively high-impedance grounded in terms of fast transients. The behaviour of the first travelling waves is comparable between the configurations within the first group while only comparable to those when the series inductors are large.

Acknowledgements The work of M. Wang and D. Van Hertem is funded by Horizon 2020 PROMOTioN (Progress on Meshed HVDC Offshore Transmission Networks) project under Grant Agreement No. 691714. The work of Jef Beerten is funded by a research grant of the Research Foundation-Flanders (FWO).

Open Access This article is distributed under the terms of the Creative Commons Attribution 4.0 International License (<http://creativecommons.org/licenses/by/4.0/>), which permits unrestricted use, distribution, and reproduction in any medium, provided you give appropriate credit to the original author(s) and the source, provide a link to the Creative Commons license, and indicate if changes were made.

Appendix A

See Table A1 and Fig. A1.

Table A1 Cable parameters

	Outer radius (mm)	ρ (Ω m)	ϵ_{rel}	μ_{rel}
Core	19.5	1.7e-8	-	1
Insulation	48.7	-	2.3	1
Sheath	51.7	2.2e-7	-	1
Insulation	54.7	-	2.3	1
Armour	58.7	1.8e-7	1	10
Insulation	63.7	-	2.3	1




Fig. A1 Cable configurations

References

- [1] ENTSO-E(2016) Ten-year network development plan 2016 executive report. <http://tyndp.entsoe.eu/projects/2016-12-20-1600-exec-report.pdf>. Accessed 15 Feb 2017
- [2] Hertem VD, Ghandhari M, Curis JB et al (2011) Protection requirements for a multi-terminal meshed DC grid. In: Proceedings of Cigré Bologna symposium, Bologna, Italy, 13–15 Sep 2011, 8 pp
- [3] Häfner J, Jacobson B (2011) Proactive hybrid HVDC breakers—a key innovation for reliable HVDC grids. In: Proceedings of Cigré Bologna Symp, Bologna, Italy, 13–15 Sep 2011, 8 pp
- [4] Tahata K, Oukaili SE, Kamei K et al (2014) HVDC circuit breakers for HVDC grid applications. In: Proceedings of the 11th IET international conference on AC and DC power transmission, Birmingham, UK, 10–12 Feb 2015, 9 pp
- [5] Davidson CC, Whitehouse RS, Barker CD et al (2015) A new ultra-fast HVDC circuit breaker for meshed DC networks. In: Proceedings of the 11th IET international conference on AC and DC power transmission, Birmingham, UK, 10–12 Feb 2015, 7 pp
- [6] Descloux J (2013) Protection contre les courts-circuits des réseaux à courant continu de forte puissance. Ph.D. dissertation, Université de Grenoble, Grenoble, France, Sep 2013
- [7] Johannesson N, Norrga S (2015) Longitudinal differential protection based on the universal line model. In: Proceedings of the 41st annual conference of IEEE industrial electronics society, Yokohama, Japan, 9–12 Nov 2015, pp 1091–1096
- [8] KerfDK, Srivastava K, Reza M et al (2011) Wavelet-based protection strategy for DC faults in multi-terminal VSC HVDC systems. IET Gener Transm Distrib 5(4):496–503. doi:10.1049/iet-gtd.2010.0587
- [9] Leterme W, Beerten J, Hertem VD (2016) Non-unit protection of HVDC grids with inductive DC cable termination. IEEE Trans Power Deliv 31(2):820–828. doi:10.1109/TPWRD.2015.2422145
- [10] Sneath J, Rajapakse AD (2016) Fault detection and interruption in an earthed HVDC grid using ROCOV and hybrid DC breakers. IEEE Trans Power Deliv 31(3):973–981. doi:10.1109/TPWRD.2014.2364547
- [11] Pirooz AS, Hertem VD (2017) A fast local bus current-based primary relaying algorithm for HVDC grids. IEEE Trans Power Deliv 32(1):193–202. doi:10.1109/TPWRD.2016.2595323

- [12] Johannesson N, Norrga S, Wikström C (2016) Selective wave-front based protection algorithm for MTDC systems. In: Proceedings of the 13th IET international conference on development in power system protection (DPSP), Edinburgh, UK, 7–10 Mar 2016, 6 pp
- [13] Cigré Working Group B4.52 (2013) HVDC grid feasibility study. Cigré Technical Brochure, April 2013
- [14] Boeck DS, Tielens P, Leterme W et al (2013) Configurations and earthing of HVDC grids. In: Proceedings of the 2013 IEEE power and energy society general meeting, Vancouver, Canada, 21–25 July 2013, 5 pp
- [15] Leterme W, Tielens P, Boeck DS et al (2014) Overview of grounding and configuration options for meshed HVDC grids. *IEEE Trans Power Deliv* 29(6):2467–2475. doi:[10.1109/TPWRD.2014.2331106](https://doi.org/10.1109/TPWRD.2014.2331106)
- [16] Wang W, Barnes M, Marjanovic O et al (2016) Impact of DC breaker systems on multiterminal VSC-HVDC stability. *IEEE Trans Power Deliv* 31(2):769–779. doi:[10.1109/TPWRD.2015.2409132](https://doi.org/10.1109/TPWRD.2015.2409132)
- [17] Morched A, Gustavsen B, Tartibi M (1999) A universal model for accurate calculation of electromagnetic transients on overhead lines and underground cables. *IEEE Trans Power Deliv* 14(3):1032–1037. doi:[10.1109/61.772350](https://doi.org/10.1109/61.772350)
- [18] Leterme W, Ahmed N, Beerten J et al (2015) A new HVDC grid test system for HVDC grid dynamics and protection studies in EMT-type software. In: Proceedings of the 11th IET international conference on AC and DC power transmission, Birmingham, UK, 10–12 Feb 2015, 7 pp
- [19] Manitoba HVDC Research Center (2016) EMTDC users guide v4.6. https://hvdc.ca/uploads/ck/files/EMTDC%20Users%20Guide%20V4_6_0.pdf. Accessed 15 Feb 2017
- [20] Ametani A (1980) Wave propagation characteristics of cables. *IEEE Trans Power Appl Syst PAS-99(2)*:499–505
- [21] Leterme W, Beerten J, Hertem VD (2016) Equivalent circuit for half-bridge MMC dc fault current contribution. In: Proceedings of 2016 IEEE energy conference (ENERGYCON), Leuven, Belgium, 4–8 April 2016, 6 pp
- [22] Wang M, Beerten J, Hertem VD (2016) DC fault analysis in bipolar HVDC grids. In: Proceedings of IEEE Benelux PELS/PES/IAS young researchers symposium, Eindhoven, Netherlands, 12–13 May 2016, 6 pp

Mian WANG is pursuing her Ph.D. in the department of Electrical Engineering in KU Leuven. She received her M.Eng. degree in

electrical engineering from Kyoto University in 2011. She worked as a Power System Engineer in Power and Industrial Systems R&D Centre Toshiba from 2011 to 2015. Her research interests are high voltage DC Transmission, multivendor DC grid protection systems.

Jef BEERTEN (S'07-M'13) received the M.Sc. degree in electrical engineering and the Ph.D. degree from the University of Leuven (KU Leuven), Belgium, in 2008 and 2013, respectively. In 2011, he was a visiting researcher at the EPS Group, KTH Royal Institute of Technology, Stockholm, Sweden for 3 months. From April 2014 until March 2015, he was a visiting postdoctoral researcher at the Power Systems Group, Norwegian University of Science and Technology (NTNU), Trondheim, Norway. Currently, he is a postdoctoral researcher with the ELECTA division of KU Leuven and EnergyVille. His research interests include power system dynamics and control and the impact of HVDC systems in particular. Dr. Beerten is an active member of both the IEEE and CIGRE. Dr. Beerten received both the KBVE/SRBE 'Robert Sinnaeve Award 2013' and the 'Prix Paul Caseau 2014' from the Institut de France—Fondation EDF for his PhD thesis on modelling and control of DC grids and was the first winner of the ABB Research Award in Honor of Hubertus von Gruenberg in 2016 for his research on HVDC grids. His work is funded by a postdoctoral fellowship from the Research Foundation—Flanders (FWO).

Dirk Van HERTEM graduated as a M.Eng. in 2001 from the KHK, Geel, Belgium and as a M.Sc. in Electrical Engineering from the KU Leuven, Belgium in 2003. In 2009, he has obtained his PhD, also from the KU Leuven. In 2010, Dirk Van Hertem was a member of EPS group at the Royal Institute of Technology (KTH), in Stockholm. Since spring 2011 he is back at the University of Leuven where he is an associate professor in the ELECTA group. His special fields of interest are power system operation and control in systems with FACTS and HVDC and building the transmission system of the future, including offshore grids and the supergrid concept. Dr. Van Hertem is an active member of both IEEE (PES and IAS) and Cigré, currently acting as chair of the IEEE Benelux section. He was the general chair of the IEEE EnergyCon 2016 conference, held in Leuven, and the chair of the steering committee of the ISGT Europe conference.