



# HVDC BREAKER EXPERIENCE IN SGCC

SC A3 Technical Panel on "HVDC circuit breakers"  
Ting An (China)



国家电网  
STATE GRID


全球能源互联网研究院有限公司

GLOBAL ENERGY INTERCONNECTION RESEARCH INSTITUTE CO.,LTD

# NEEDS & REQUIREMENTS

## MT-HVDC systems & DC Grids


- (1) Faults in the AC side of the I/T
- (2) Faults within converter valves
- (3) DC faults



## 3 challenges faced by HVDC Circuit Breakers


- How to interrupt a DC current without zero crossings ?
- How to interrupt a DC current within very short period (2-3ms) to protect PE devices & prevent spread over of faults ?
- How to limit overvoltages and dispose the energy stored in the system ?

- ✓ Zero crossings vs **No zero crossings**
- ✓ Higher vs **lower** impedance
- ✓ Amp decays vs **rises** quickly




# TYPES OF DC CIRCUIT BREAKERS

## Mechanical DC Circuit Breakers




- Zero-crossings created via LC circuit
- Arc interrupted: long breaking time with low on-state losses

## Hybrid DC Breakers



- Formed by ultra-fast mechanical AC disconnecter & semiconductor switches
- Low on-state losses & fast break features

## CNV Hybrid DC Breakers



- Inject opposite DC current by coupling neg. volt (CNV) circuit
- UFB arc interrupted at zero crossing, current diverted to electronic SW
- UFB needs to withstand transient V

# APPLICATION OF DCCB FOR ZHOUSHAN

## Zhoushan HVDC system

- $\pm 200\text{kV}/1000\text{MW}$
- 400/300/100/100/100MW
- DC cables
- Commissioned in July 2014
- Securing reliable power supply to five islands
- Integration of offshore WF



## H DCCB

- 200kV DC breaker prototype developed by GEIRI in 2014
- Rated current: 2kA
- Max DC breaking current: 15kA
- Min breaking time: 3ms
- Max. energy to be absorbed: 4MJ
- Module design: 4\*50kV

✎ The max. P-P DC S/C at converter side of the DC CB: **10kA**

✎ The max. P-E over-voltage under P-G fault: **400kV**




# APPLICATION OF DCCB FOR ZHOUSHAN


- To clear the faults in the converter station
- To limit the fault current
- To maintain stable continuing operation
- To realize STATCOM mode under AC grid faults & DC side faults
- To achieve live switch on/off at Zhoushan terminal






# APPLICATION OF DCCB FOR ZHOUSHAN



Fast Mechanic Switch



Main Branch Module




Transfer Branch Module

Successful installation of 200kV DC Breaker in 2016




# APPLICATION OF DCCB FOR ZHOUSHAN

- DC cable was pulled out and damaged
- Cable was repaired
- Converter was de-blocked
- Repair was not undertaken properly
- Negative pole to ground fault occurred during charging process
- System detected the fault
- DC CB tripped





# APPLICATION OF DCCB FOR ZHOUSHAN







# APPLICATION OF DCCB FOR ZHANGBEI

- ❑ Zhangbei VSC-HVDC project,  $\pm 500\text{kV}$ , 4 terminals, Symmetric bipolar
- ❑ Zhangbei (3000MW) & Kangbao (1500MW) as sending stations (WP & SP)
- ❑ Fengning (1500MW) as ES & Beijing (3000MW) as receiving station
- ❑ Expandable DC grid in the future (7T), OHL
- ❑ Half bridge MMC + DC breakers, isolating DC line fault by DC breakers
- ❑ 4 breakers each station,  $4 \times 4 = 16$  DC CB in total




# APPLICATION OF DCCB FOR ZHANGBEI


- ❑ To be manufactured by 5 companies
- ❑ 3 different technologies :
  - 2 \* Mechanical DC Circuit Breakers by one manufacturer
  - 12 (4+8) \* Hybrid DC Breakers by two manufacturers
  - 2 \* Coupling Negative Voltage (CNV) Hybrid DC Breakers by one manufacturer




Item	Parameters
Vr	535kV
Ir	3.3kA
B T	2.53ms
B I	26kA
R T	300ms
TRV	810kV




# APPLICATION OF DCCB FOR ZHOUSHAN




Interruption test circuit




Interruption test facility



Reclosing test waveforms



1<sup>st</sup> interruption



2<sup>nd</sup> interruption



# Thank you!

